

CERTIFICATE OF CONFORMITY



Certificate No. CTK20190530003LVD

Certificate's Holder : **ARVI**
Address : R. Noé Pereira, 473
4510-706 Fânzeres, Portugal

Product Name : **Ceramic Terminal Block**
Model(s) : For details see the appendix

Applicable : EN 60998-1:2004
Standard(s) : EN 60998-2-1:2004

The submitted products have been tested by us with the above standards and found in compliance with the following European Directives:

Low Voltage Directive 2014/35/EU

Note: This certificate is only valid for the equipment and configuration described, and in conjunction with the test data detailed above. The CE mark as show joined can be used, under the responsibility of the manufacturer or the importer, after completion of the CE Declaration of Conformity and in accordance with the above directives.

Issued Date: 18.06.2019
Updated Date: 24.07.2024
Expiry Date: 17.06.2029



Thomas Diong
Thomas Diong
Chief Certification Manager

GUANGZHOU CERTITEK TESTING SERVICES CO., LTD.

Room703/7F, Development Building, Tian An Hi-Teck Ecological Park

No.555 North Road Panyu Avenue, Panyu District, Guangzhou, 511400, China

+86 20 3921 1670 +86 20 3921 1640 Info@certitek.cn www.cktest.com V5.0

Appendix



Certificate No. CTK20190530003LVD

Page 1 of 1

Specifications:

Inserts: Nickel plated brass
Housing: Ceramic (Glazed Option)
Temp: 800°C(Housing), 350°C(Inserts)
Screws: Galvanized Steel
Standard: EN 60998-1; EN 60998-2-1
Color: White
Feature: Hard and solid

Models	Cross Section	Current Range	Rated Voltage
BJP-5A-1P	4 mm ²	5~32A	450V
BJP-5A-2P	4 mm ²	5~32A	450V
BJP-5A-3P	4 mm ²	5~32A	450V
BJP-5A-4P	4 mm ²	5~32A	450V
BJP-10A-1P	6 mm ²	10~32A	450V
BJP-10A-2P	6 mm ²	10~32A	450V
BJP-10A-3P	6 mm ²	10~32A	450V
BJP-15A-1P	10 mm ²	15~57A	450V
BJP-15A-2P	10 mm ²	15~57A	450V
BJP-15A-3P	10 mm ²	15~57A	450V
BJP-15A-4P	10 mm ²	15~57A	450V
BJP-30A-1P	16 mm ²	30~76A	450V
BJP-30A-2P	16 mm ²	30~76A	450V
BJP-30A-3P	16 mm ²	30~76A	450V
BJP-30A-4P	16 mm ²	30~76A	450V

GUANGZHOU CERTITEK TESTING SERVICES CO., LTD.

Room703/7F, Development Building, Tian An Hi-Teck Ecological Park

No.555 North Road Panyu Avenue, Panyu District, Guangzhou, 511400, China

☎ + 86 20 3921 1670 📠 + 86 20 3921 1640 ✉ Info@certitek.cn 🌐 www.ckttest.com V5.0